

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF BRACKEN COUNTY)	
WATER DISTRICT NO. 1 FOR APPROVAL)	
OF A DEVIATION FROM THE REQUIREMENTS)	CASE NO. 91-112
OF TESTING ITS LARGER METERS AND TO)	
PROVIDE LESS WATER STORAGE)	

O R D E R

By letter filed on March 31, 1994, Bracken County Water District No. 1 ("Bracken Water") requested a time extension to comply with Commission Regulation 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. On June 11, 1991, the Commission ordered Bracken Water to bring its water storage facilities into compliance with Commission regulations by July 1, 1994.

On March 31, 1994, Bracken Water informed the Commission that it has been actively pursuing methods for complying with the Commission's regulations. In that regard, Bracken Water's engineering consultant has been authorized to prepare construction plans and specifications for additional water storage facilities. Bracken Water's engineering consultant anticipates construction being finished by December 31, 1994.

The Commission, having reviewed the information submitted and being otherwise sufficiently advised, finds that Bracken Water is making a good faith effort toward bringing its facilities into

compliance with Commission regulations and that additional time is necessary to comply with the requirements of Commission Regulation 807 KAR 5:066, Section 4(4).


IT IS THEREFORE ORDERED that:


1. Bracken Water be and it hereby is granted a deviation until December 31, 1994 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Bracken Water shall take all necessary action to bring its water storage facilities into compliance with Commission regulations prior to December 31, 1994.

Done at Frankfort, Kentucky, this 20th day of April, 1994.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director